

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 50526399

Blatt *Sheet*
0002

Ihr Zeichen *Client Reference*
H.G.

Unser Zeichen *Our Reference*
01-HUELL-CN217IYY 003

Ausstellungsdatum *Date of Issue*
01.03.2023 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Gazioğlu Solar Enerji San.
ve Tic. A. Ş.
Gaziosman Paşa Mah.7.cd
No. 124 Çerkezköy
59500 Tekirdağ
Turkey

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



IEC 61215
IEC 61730
Regular Production
Surveillance

www.tuv.com
ID 1111245967

Geprüft nach *Tested acc. to*

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
EN 61215-1:2016
EN 61215-1-1:2016
EN 61215-2:2017
EN IEC 61730-1:2018
EN IEC 61730-2:2018

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

PV Module

Type Designations:

Max. System Voltage: Up to 1500 VDC (Voc at STC):

With 1/2 cut of mono c-Si cells:

GSEGxxx-120M (xxx=580-610, in steps of 5, 120 cells)

GSEGxxx-108M (xxx=525-545, in steps of 5, 108 cells)

GSEGxxx-96M (xxx=470-485, in steps of 5, 96 cells)

GSExxx-144M (xxx=520-560, in steps of 5, 144 cells)

GSExxx-132M (xxx=480-510, in steps of 5, 132 cells)

GSExxx-120M (xxx=435-465, in steps of 5, 120 cells)

GSExxx-108M (xxx=390-420, in steps of 5, 108 cells)

Remarks:

Safety Factors: 1.5

Design Load (Refer to test report for details of
corresponding material and installation method.):

3600 Pa (downward) / 1600 Pa (upward)

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

